

No:- CMO/M-105/2025-26

Date :25/03/2026

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

It is certified that an inspection team headed by Abhay Dubey from CMO office near commisionary chowk Meerut U.P. – 250001 PHED inspected the S R INTERNATIONAL SCHOOL VILL NANGLA SAHOO, POST JAEK KILA PARIKSHITGARH ROAD, BLOCK MACHHRA, MEERUT on 25/03/2026 and on the basis of Water Test Report (Attached) bearing no 799513324 dated 23/03/2026 of Shankar Laboratories certified that the S R INTERNATIONAL SCHOOL has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 24/03/2027.

Signature with Seal:

Name :

Designation :

Name & Address of the Office / Department :.....


करो मुख्य शिक्षा अधिकारी
मेरठ

To

S R INTERNATIONAL SCHOOL
VILL NANGLA SAHOO, POST JAEK
KILA PARIKSHITGARH ROAD,
BLOCK MACHHRA, MEERUT



Shanker Laboratories

Known for Excellency in Testing
(NABL Accredited)



TC-6113

Report No: 799513324
Issued to:
SR International School
Kila Parikshit Road, Meerut

Date: 23.03.2026

Party's Ref No: Nil
Job Order: SL/CH/799513324,
Dt.: 16.03.2026

Sample Description: Drink Water Sample (Water Cooler Pentry)

Type of Unit : Imaging Centre
Sample Type : Water
Sample Locating : Water Cooler (Pentry)
Date of Sampling : 16.03.2026
Date of Receipt of Sample : 20.03.2026

Sample Quantity : 2 Litre + 250 ml in Sterilized bottle
Purpose of Analysis : Monitoring
Sample Collected/Supplied By : By our Lab Representative
Period of Testing : 16.03.2026 to 20.03.2026
Reference to Protocol : IS 10500: 2012 Amendment No. 1, June 2015

TEST RESULTS

| Sr. No. | Organoleptic and Physical Parameter | Results | Acceptable Limit | Permissible Limit | Protocol Used |
|--|--|---------------|------------------|-------------------|---------------------|
| 1 | Colour, Hazen units | 1 | 5 max | 15 max | IS 3025 (P-4) 1983 |
| 2 | Odour | Agreeable | Agreeable | Agreeable | IS 3025 (P-5) 1984 |
| 3 | Turbidity, NTU | <1.0 | 1 max | 5 max | IS 3025 (P-10) 1984 |
| 4 | pH | 8.15 | 6.5 - 9.5 | No Permission | IS 3025 (P-16) 1984 |
| 5 | Total Dissolved Solids, mg/l | 134.0 | 500 max | 2000 max | IS 3025 (P-16) 1984 |
| General Parameters Concerning Substances Undesirable in excessive amounts (mg/l) | | | | | |
| 6 | Total Hardness (as CaCO ₃) | 80.0 | 200 max | 600 max | IS 3025 (P-21) 2009 |
| 7 | Chloride (as Cl) | 7.99 | 250 max | 2000 max | IS 3025 (P-32) 1986 |
| 8 | Residual Free Chlorine | BDL (DL 0.05) | 0.2 min* | 1 min | IS 3025 (P-26) 1986 |
| 9 | Iron (as Fe) | BDL (DL 0.02) | 1.0 max | No Reflection | IS 3023 (P-53) 2003 |
| 10 | Total Alkalinity (as CaCO ₃) | 69.36 | 200 max | 600 max | IS 3023 (P-23) 1986 |
| Bacteriological Quality | | | | | |
| 1 | Coliform Organisms, MPN/100ml | Absent | Absent | No Reliction | IS 1922 - 1982 |
| 2 | E-Coli, (per 100ml) | Absent | Absent | No Reliction | IS 1922 - 1982 |

Remarks:

- Analyzed parameters of water samples confirms to IS 10500:2013 specification with respect to above test parameters.
- *if sample is Chlorinated.
- BDL: Below Detection Limits / DL : Detected Limit.

कृते मुख्य चिकित्सा अधिकारी,
मेरठ

Dr. N. K. Katiyar
Authorized Signatory (CEO)
Ex-Change Analytical Lab Services™
National Council for Cement and Building Materials